



(1) **EC-TYPE-EXAMINATION CERTIFICATE**
(Translation)

(2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres - **Directive 94/9/EC**



(3) EC-type-examination Certificate Number:

PTB 03 ATEX 2018 X

(4) Equipment: Solenoid, type 0515.. and type 1215..

(5) Manufacturer: Nass Magnet GmbH

(6) Address: Eckenerstraße 4-6, 30179 Hannover, Germany

(7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

(8) The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report PTB Ex 03-21355.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014:1997 + A1 + A2

EN 50028:1987

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-type-examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the equipment shall include the following:




II 2 G

EEx m II T6, T5 or T4

Zertifizierungsstelle Explosionsschutz

Braunschweig, June 16, 2003

By order:


Dr.-Ing. U. Johannsmeyer
Regierungsdirektor



(13)

SCHEDULE

(14)

EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2018 X

(15) Description of equipment

The solenoid consists of a magnet coil, an armature system and a fixing nut. The armature guide forms the pressure-proof part of the magnet, the guide tube is tested at 1.5 times the nominal operating pressure. The guide tube is specified either for thread-mounting or flange-mounting. The winding consists of varnished copper wire of insulation class H. This coil is injection-moulded with pre-plastified granules. A circuit board with electronic components is soldered onto the terminal posts of the encapsulated part of the coil. The terminals are mounted into a housing made of glass-fibre-reinforced polyimide 6 and casted afterwards.

Electrical data

Type designation	0515..
Type of current	alternating current
Nominal voltage	12 V ... 240 V
Nominal current	0,158 A ... 0,010 A
Steady-state active power	2,3 W
Max. perm. ambient temperature	50 °C
Temperature class	T6
Frequency	50 Hz...60 Hz
Medium temperature	50 °C
Single mounting	yes

Type designation	0515..
Type of current	alternating current
Nominal voltage	12 V ... 240 V
Nominal current	0,158 A ... 0,010 A
Steady-state active power	2,3 W
Max. perm. ambient temperature	40 °C
Temperature class	T6
Frequency	50 Hz...60 Hz
Medium temperature	40 °C
Group mounting	yes, wall to wall

Type designation	1215..
Type of current	direct current
Nominal voltage	6 V ...220 V
Nominal current	0,435 A ... 0,012 A
Steady-state active power	2,5 W
Max. perm. ambient temperature	50 °C
Temperature class	T6
Medium temperature	50 °C
Single mounting	yes

sheet 2/5

Type designation	1215..
Type of current	direct current
Nominal voltage	6 V ...220 V
Nominal current	0,435 A ... 0,012 A
Steady-state active power	2,5 W
Max. perm. ambient temperature	40 °C
Temperature class	T6
Medium temperature	40 °C
Group mounting	yes, wall to wall

Type designation	0515..
Type of current	alternating current
Nominal voltage	12 V ... 240 V
Nominal current	0,212 A ... 0,015 A
Steady-state active power	3,4 W
Max. perm. ambient temperature	50 °C
Temperature class	T5
Frequency	50 Hz...60 Hz
Medium temperature	50 °C
Single mounting	yes

Type designation	0515..
Type of current	alternating current
Nominal voltage	12 V ... 240 V
Nominal current	0,212 A ... 0,015 A
Steady-state active power	3,4 W
Max. perm. ambient temperature	40 °C
Temperature class	T5
Frequency	50 Hz...60 Hz
Medium temperature	40 °C
Group mounting	yes, wall to wall

Type designation	1215..
Type of current	direct current
Nominal voltage	6 V ...220 V
Nominal current	0,531 A ... 0,014 A
Steady-state active power	3,3 W
Max. perm. ambient temperature	50 °C
Temperature class	T5
Medium temperature	50 °C
Single mounting	yes

Type designation	1215..
Type of current	direct current
Nominal voltage	6 V ...220 V
Nominal current	0,531 A ... 0,014 A
Steady-state active power	3,3 W
Max. perm. ambient temperature	40 °C
Temperature class	T5
Medium temperature	40 °C
Group mounting	yes, wall to wall

Type designation	0515..
Type of current	alternating current
Nominal voltage	12 V ... 240 V
Nominal current	0,380 A ... 0,024 A
Steady-state active power	4,6 W
Max. perm. ambient temperature	60 °C
Temperature class	T4
Frequency	50 Hz...60 Hz
Medium temperature	80 °C
Single mounting	yes
Group mounting	yes, wall to wall

Type designation	1215..
Type of current	direct current
Nominal voltage	6 V ...220 V
Nominal current	0,815 A ... 0,027 A
Steady-state active power	5,0 W
Max. perm. ambient temperature	50 °C
Temperature class	T4
Medium temperature	80 °C
Single mounting	yes
Group mounting	yes, wall to wall

(16) Test report PTB Ex Ex 03-21355

(17) Special conditions for safe use


A fuse corresponding to its rated current (max. $3 \cdot I_{\text{rat}}$ according IEC 60127-2-1) or a motor protecting switch with short-circuit and thermal instantaneous tripping (set to rated current) shall be connected in series to each solenoid as short circuit protection. For very low rated currents of the solenoid the fuse of lowest current value according to the indicated IEC standard will be sufficient. The fuse may be accommodated in the associated supply unit or shall be separately arranged. The rated voltage to the fuse shall be equal to or greater than the stated rated voltage of the magnet coil. The breaking capacity of the fuse-link shall be as high as or higher than the maximum expected short circuit current at the location of the installation (usually 1500 A). A maximum permissible ripple of 20 % is valid for all magnets of direct-current design.

(18) Essential health and safety requirements

met by compliance with the standards mentioned above

Zertifizierungsstelle Explosionsschutz

By order:



Dr.-Ing. U. Johannsmeyer
Regierungsdirektor



Braunschweig, June 16, 2003